

1. **Question:** What are the flow and head pressure requirements for the pumps in the station?

**Answer:** Pumps shall be 500 GPM at 36' TDH (Total Dynamic Head, which includes static and friction heads).