

ADDENDUM NO. 2

February 2, 2017

RE: **MAHG 151109 Renovate McClelland Hall**
Keesler Air Force Base
Biloxi, Mississippi

This Addendum consists of 1 page, 3 Specification Sections and 0 Drawing Sheets.

CHANGES TO PROJECT MANUAL:

1. **SECTION 23 09 23.13 20 BACnet DIRECT DIGITAL CONTROL SYSTEMS FOR HVAC MATERIALS**; Delete the specification section in its entirety and replace with the attached, Note para 1.3.b: Provide DDC systems that are compatible with Johnson Controls Metasys, Provide a fiber optic-to-ethernet converter to interface with the new connection to the existing base system(s) The finished DDC system shall allow for 100% remote monitoring and remote adjusting and programming of not only the system at McClelland Hall, but also the relationship of that facility and the central plant that serves it. This includes, but is not limited to, McClelland Hall's virtual plant designation. The contractor shall demonstrate that the new system is 100% compatible and performs all existing functions before the system is accepted. Any additional material and labor required to achieve compatibility will be at the contractor's expense.
2. **SECTION 28 08 10 ELECTRONIC SECURITY SYSTEM ACCEPTANCE TESTING**; Delete the specification section in its entirety and replace with the attached, "28 08 10 ELECTRONIC SECURITY SYSTEM ACCEPTANCE TESTING."
3. **SECTION 28 10 05 ELECTRONIC SECURITY SYSTEMS (ESS)**: Delete the specification section in its entirety and replace with the attached, "28 10 05 ELECTRONIC SECURITY SYSTEMS (ESS)."

QUESTIONS AND ANSWERS:

1. Per finish schedule, ceiling tile to ne Armstrong Calla; however, specs call for "Fine Fissured School Zone #1717". Please advise.
A: Use Fine Fissured School Zone #1717 throughout.
2. Please advise on the corner guard heights.
A: See Addendum 1
4. Please advise on the corner guard wing size.
A: 2"
5. What parts of the security system are included in this project?
A: Only the Cameras and noise generators are included. The intrusion detection and access control will be under separate contract.

END OF ADDENDUM 2