

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 08-Aug-2017	4. REQUISITION/PURCHASE REQ. NO. F2JTF7145AW01		5. PROJECT NO.(If applicable)	
6. ISSUED BY 81ST CONTRACTING SQUADRON SSGT MAXWELL WATANGA 310 M STREET, RM 102 KEESLER AFB MS 39534-2701		CODE FA3010	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. FA301017R0021
				<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 13-Jul-2017
				<input type="checkbox"/>	10A. MOD. OF CONTRACT/ORDER NO.
				<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. <p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment is to: 1. Provide Questions & Answers 2. Replace SOW dated 23 May 17 w ith SOW Rev A dated 3 Aug 17 3. Replace page 6 of 9 in attachment 2 w ith new one, adding keyed notes 11 and 12					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 08-Aug-2017

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

QUESTION & ANSWERS

Building 4221 Renovate Rooms AMX

MAHG 16-9004--Keesler AFB, MS

Q&A

1. Drawing A1.0 Key note 1 for rooms 141, 154/156, 155/168 indicate solid core wood doors. In the SOW for these rooms call for hollow metal doors. Please clarify.
A: 154/156 and 155/168 to be Hollow Metal doors. Paint to match.
2. If wood doors, prefinished or finished on site?
A: Contractor must match existing door color and finish. It is the contractors option on how to achieve that.
3. Drawing A1.0 room 150 no ceiling height provided
A: Assume 9'-0" per General Notes.
4. As per the statement of work document provided 1.12 room 105, 105B and 105C statements do not match what was described on the walk thru. Please clarify if there are any changes to the Statement of Work.
A: There is no modular furniture in Rooms 105 and 105B. Additionally, the rooms numbers for 105 and 105C are reversed in the drawings. RevA of the SOW is corrected.
5. The drawings have a statement on general notes "Contractor to Paint all walls in renovated rooms covered under this contract unless noted otherwise." On the statement of work several rooms get renovations, but no paint is listed, for example 154/155. Please clarify which rooms are not covered under this note.
A: Only paint rooms indicated to receive paint in SOW.
6. The rooms are currently occupied. What is the plan to clear the room for construction activities ? Who is responsible for moving furniture, removing pictures, white board etc from the walls ? Will the moved furniture then be covered or do we need to provide covers to protect from wet paint.
A: User will move furniture, electronics, and small wall "art". Contractor shall remove and remount whiteboards and larger wall items. Contractor will move aside and protect remaining items in rooms receiving minimal work.
7. Will all rooms be available at one time or is there a sequence of availability? The Painting portion of the scope as reviewed today will only take a few days unless they are unavailable due to scheduling.
A: Rooms 105, 105B, and 105C will be done one at a time with rooms 119, 120, and 123 done in between. All others can be done anytime and in any sequence indicated on the schedule.
8. Room 123 who will remove the lockers to access the walls behind?
A: The Contractor
9. Room 141 gets a new wall as it is currently an open area. The new wall, inside and outside of the room needs to be painted Correct?
A: Correct, as noted in the SOW.
10. What happens to the Fire Extinguisher cabinet in room 154 if it conflicts with the new door?

A: If conflict occurs between new door and existing fire extinguisher cabinet, contractor shall coordinate with the project inspector to field locate door opening.

11. Will additional sprinkler heads be required in room 141.

A: Yes, two additional heads will be required in Rm 141. Also, the three existing heads in the hallway will need to be centered in the hallway. See SOW RevA

12. The SOW and Drawings have conflicting amounts of finish work to be done in Rm150. What work is to be done there?

A: Include the finish work indicated in the Drawings which has been added to the SOW RevA.

SECTION A - SOLICITATION/CONTRACT FORM

The required response date/time has changed from 14-Aug-2017 11:00 AM to 16-Aug-2017 02:00 PM.

SECTION J - LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS

The following have been modified:

SECTION J

Document Type	Description	Pages	Date
Attachment 1	Specifications, MAHG16-9004	97	17 Mar 17
Attachment 2	Drawings, MAHG16-9004, page 6 revised	9	18 May 17
Attachment 3	Statement of Work (SOW)	19	3 Aug 17
Attachment 4	Wage Determination, MS170119	5	7 July 2017
Attachment 5	SF 1444 w/ Instructions	3	Undated
Attachment 6	Notice of Compliance	2	Undated
Attachment 7	Past Performance Reference List	1	07 Jul 17
Attachment 8	Past Performance Questionnaire (PPQ)	3	Undated

(End of Summary of Changes)