

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	3
2. AMENDMENT/MODIFICATION NO. 0005	3. EFFECTIVE DATE 28-Mar-2018	4. REQUISITION/PURCHASE REQ. NO. F2JTF A7340AW01		5. PROJECT NO.(If applicable)	
6. ISSUED BY 81ST CONTRACTING SQUADRON TSGT MARCOS A. MORALES 310 M ST KEESLER AFB MS 39534	CODE FA3010	7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) <b>GSI Construction Corporation, Inc.</b> <b>2993 Wallace Lake Road</b> <b>Pace, FL 32571 - Santa Rosa County</b> <b>DUNS: 078278816 CAGE: 6LFP6</b>			X	9A. AMENDMENT OF SOLICITATION NO. FA301018R0013	
			X	9B. DATED (SEE ITEM 11) 31-Jan-2018	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.					
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  The purpose of this amendment is to incorporate questions and answers and add addendum #2.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print) <b>Josh Owens, President</b>			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED <b>28-MAR-2018</b>	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 28-Mar-2018	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

QUESTIONS AND ANSWERS 2

\*1. Drawing E-801 is showing a 400amp 3 pole NEMA3R manual transfer switch. Is this a service entrance rated switch? And is over current protection required for the manual transfer switch? What size and type of overcurrent protection is required?

A: On the riser, the enclosed breaker/disconnect needs to be moved ahead of the transfer switch. That will be the overcurrent protection and the service disconnect for the building.

\*2. Drawing E-801 the one line is showing the 400amp enclose circuit breaker on the load side of the manual transfer switches. The answer for question 20 state the specification for the manual transfer switch " heavy duty NEMA 3R double throw switch" and doesn't mention any overcurrent protection requirements. The Services entrance 400amp breaker should be ahead of the manual transfer heavy duty NEMA 3R double throw switch this would provide the overcurrent protection require. Also with the enclose 400amp circuit breaker ahead of the manual transfer switch in the event of power outage the breaker could be locked out and the generator connected to the manual transfer switch and the build transfer to generator. Than once normal restore and the main 400amp breaker still lock out the generator could be turn off and disconnected from the manual transfer switch without having to work in the manual transfer while it energize. The current design once normal power is restore the manual transfer switch will have power present while disconnecting the generator cable unless the transformer has been turn off. Also this would eliminate the need for overcurrent protection require for the manual transfer.

A: On the riser, the enclosed breaker/disconnect needs to be moved ahead of the transfer switch. That will be the overcurrent protection and the service disconnect for the building.

3. Please confirm that email submittal of proposal should go to [marcos.morales2@us.af.mil](mailto:marcos.morales2@us.af.mil), Should other recipients be included?

A: You can also include [kimberley.alvarez.1@us.af.mil](mailto:kimberley.alvarez.1@us.af.mil)

4. What is the email size limitation for the proposal recipient(s)?

A: Any email over 10MB should be sent through AMRDEC (<https://safe.amrdec.army.mil/safe/>)

5. May AMRDEC (<https://safe.amrdec.army.mil/safe/>) be used to submit the proposal, or is email the only acceptable means for electronic submittal?

A: Due to potential size of offers and email security, AMREC is encouraged for electronic submission of proposals.

\*Due to misalignment/overwriting, Drawing E-601 appears to be E-801. There is no E-801; all references to E-801 shall be understood as E-601.

## SECTION J - LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS

The following have been modified:

LIST OF DOCUMENTS

<u>Document Type</u>	<u>Description</u>	<u>Pages</u>	<u>Date</u>
Attachment 1	Specifications, MAHG179002	789	10 Nov 17
Attachment 2	Drawings MAHG179002	35	10 Nov 17
Attachment 3	Wage Det MS180141	5	5 Jan 18
Attachment 4	Past Performance Questionnaire	3	Undated
Attachment 5	Past Performance Reference List	1	Undated
Attachment 6	Notice of Compliance	2	Undated
Attachment 7	SF 1444	3	Undated
Attachment 8	Addendum 1	1	19 Mar 18
Attachment 9	Addendum 2	1	27 Mar 18

(End of Summary of Changes)