

**March 27, 2018**  
**ADDENDUM #2**

The following sheet has been changed in the construction documents for the following project:

**MAHG17-9002 36 AES Warehouse**  
**KEESLER AFB, MISSISSIPPI**

Any information found within these documents shall take precedent over the information contained within the original construction documents. It is the responsibility of the contractor to review the documents and to include any revised or additional information in their proposal.

**Changes to the drawings:**

E601, One Line Detail: Move the 400amp breaker ahead of the manual transfer heavy duty NEMA 3R double throw switch.