

PRE AWARD ADDENDUM 1

Solicitation FA441719RA013  
CP1026752 REPAIR COMMAND POST 1 SOAOS BLDG 90208  
6 Sep 2019

1. Add temporary partition to separate construction phases similar to wall type 1 on sheet A-001 but extend partition to structure above in order to enhance sound and dust control during the extent of work between room #128 Battle Staff and room #129 JPG.
2. Add temporary air conditioning connected to existing ductwork for each phase of construction as required for building users to occupy adjacent spaces during the downtime for air handler replacement.