

NPS response to prospective Contractor's Questions to clarify NPS requirements:

1. Are all the fasteners, straps and connectors to be stainless steel including the truss plates, or can the truss plates be galvanized?

*Yes, truss plates can be galvanized, rationale; truss plates will be above the sealed plywood ceiling. (please state which type toe offer price is based upon)*

2. The Langdon Beach SOW says to replace the railing and pickets with treated lumber. Are the aluminum handrails being replaced with new, or are the existing aluminum handrails to be replaced and placed back on the wood railings and pickets?

*The contractor can be removed and reinstalled the existing aluminum handrails.*