



DEPARTMENT OF THE AIR FORCE
HEADQUARTERS 16th SPECIAL OPERATIONS WING (AFSOC)

MEMORANDUM FOR 16 SVS/SVYC
ATTENTION: MRS VIRGINIA GREEN

21 FEB 1995

FROM: 16 SPTG/CE
415 Independence Road, Building 90053
Hurlburt Field, FL 32544-5244


SUBJECT: Lead Based Paint Clearance for Building 90353
(Child Development Center)

1. All painted surfaces accessible to small children in subject facility have been tested using a Spectrum Analyzer Lead Detector (XRF). Identified surfaces that exceeded the Housing and Urban Development action limit of 1.0 mg/cm² have been removed from the building. Clearance testing was performed on 20 Feb 95, with negative results.

2. Please refer any questions to MSgt Ermes at (904) 884-4651.

"ORIGINAL SIGNATURE"

PHILIP J. LE GRAND, Lt Col, USAF
Base Civil Engineer

CEV 

THIS CLEARANCE REQUIRED TO OBTAIN CERTIFICATIONS
TO LICENSE THE FACILITY.


22 FEB 95

Any Time . . . Any Place