



## ADDENDUM II

ITB NO: 22-026A

ITB TITLE: CHOCTAW BEACH FIRE STATION

**ADDENDUM NO: II**

**DATE: February 9, 2023**

PLEASE BE ADVISED THAT THE FOLLOWING CHANGES ARE APPLICABLE TO THE ORIGINAL SPECIFICATIONS OF THE ABOVE REFERENCED ITB

- ITB closing date of February 23, 2023 has been postponed until completion of the Phase II Archaeological Testing and County has received the subsequent approval to proceed.
- Phase II Archaeological: Walton County (via Dewberry Contract) has entered into a contract with TerraXplorations Inc. for testing. Based on their proposal, it is anticipated that the study will take approximately 13 weeks to complete. Once the County is cleared to move forward, we will notify all bidders, they will have two weeks (14 calendar days) to submit their final bids.
- Sheet L1.2 – Landscape Plan has been updated to show limits of proposed sod.
- Bid Schedule has been revised to account for updated Sod quantity.
- Sheet A1.1 – Floor Plan has been revised. Revisions were made to the Room Finish Schedule. The Bunks, Conference Room, Rec. Room, Dining Area, and Utility Closet will have epoxy finished floors. The Garage, Gear Room, Comp. Room, and Sprinkler Room will have sealed concrete floors.
- Sheet A1.4 – Elevations has been revised. Revisions were made to the exterior wainscoting. Brick wainscoting is no longer proposed. Provide colored metal wainscot and metal trim.
- Section 09670 Fluid Applied Resinous Flooring has been added to the updated technical specifications.
- Section 03390 Curing, Sealing, and Hardening Concrete Floors has been added to the updated technical specifications.
- Section 07416 Standing Seam Metal Roofing System has been removed from the updated technical specifications.
- Section 09910 Light Commercial/Residential Painting has been added to the updated technical specifications.
- Section 13000 Metal Building Systems has been added to the updated technical specifications.
- Appendix E – Roof Panel Installation Guide has been added to the updated technical specifications.

Link to the plans and specifications can also be found in the ITB (page 2).

<https://waltoncountyclerk.sharefile.com/d-s351c09fe1dcb4824afcba82a6e3a7a18>



**THIS ADDENDUM NOW BECOMES A PART OF THE ORIGINAL RFP. YOU MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND SUBMIT WITH YOUR PROPOSAL, FAILURE TO DO SO WILL SUBJECT THE BIDDER TO DISQUALIFICATION.**

FIRM: \_\_\_\_\_ BY: \_\_\_\_\_

ADDRESS: \_\_\_\_\_ PHONE: \_\_\_\_\_

CITY, STATE, \_\_\_\_\_ DATE: \_\_\_\_\_

EMAIL ADDRESS: \_\_\_\_\_

\_\_\_\_\_  
Authorized Signature

DRAFT