



June 10, 2024

ADDENDUM NO. 1

CHOCTAW COUNTY JAIL  
BUTLER, ALABAMA

This Addendum No. 1, to the plans and specifications, dated May 30, 2024, consists of One (1) Page.

Item No.1: Refer to Advertisement for Bids:

- A. PRE BID DATE CHANGE: A **PRE-BID CONFERENCE** will be held in the Conference Room at the Choctaw County Courthouse Meeting Room, 117 S. Mulberry Avenue, Butler, Alabama 36904 on **June 17, 2024 at 2:00 PM** (local time prevailing) for the purpose of reviewing the project and answering Bidder's questions. Attendance at the Pre-Bid Conference is highly recommended for all Contract Bidders intending to submit a Bid.

Item No. 2: Refer to Specifications:

- A. Contractors shall provide undercut and compacted fill a minimum of 2 feet (24 inches) average across the building pad area. Contractor shall include this cost and scope in their base bid. Adjustments to undercut depth / volume may be required after excavation and proofroll. Any adjustments of quantity / depth / volume of undercut and fill shall be made utilizing contractor's Unit Price submitted with Bid.

END OF ADDENDUM NO. 1